



TENT PERMIT CONDITIONS

- Tents shall be permitted only on a temporary basis.
- All tent fabric shall meet the flame propagation performance criteria contained in NFPA 701, certificate of such shall be provided at time of permit application.
- There shall be a minimum of 10 ft. between stake lines.
- Adjacent tents shall be arranged to provide space for emergency egress.
(Exception: tents in excess of 1,200 sf on ground level, located in an open space and meeting all other safety precautions)
- The ground inside of any tent and all ground within a minimum of 10 ft. around the tent shall be clear of and kept free from all flammable or combustible material or vegetation.
- Smoking shall not be permitted in any tent.
- Portable fire-extinguishing equipment of approved types shall be furnished and maintained in tents in such quantity and in such locations as directed by the authority having jurisdiction.
- Containers for liquefied petroleum gases shall not be installed within 60 in. of any tent and shall be in accordance with the provisions of NFPA 58. Tanks shall be secured in an upright position and protected from vehicular traffic.